



SEE DWG# 26690 FOR SCHEMATIC

UNIT SPECIFICATIONS:					
KVAR	HARMONIC	VOLT	HZ	PHASE	HP
45	5TH	480	60	3	150
ENCLOSURE		WHITE OPEN PANEL			
APPROX.WT. LBS.		265			

SYMBOL	TCI PART NUMBER
LR	KDRL2T
TR	KTR45A65HG
CAP.1, CAP.2 (20 KVAR)	KCAP20A6B
CAP.3 (5 KVAR)	KCAP5A6A
XFMR.	23891
Fu1,2,3	11077
Fu4,6	21270
Fu5	13364
CNT	19246



CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS. CAPACITORS MAXIMUM AMBIENT 50°C.

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

				TOLERANCES EXCEPT AS NOTED	7878 N. 86th STREET MILWAUKEE, WI 53224
				.XX ± .03 .XXX ± .01 FUNCTIONAL ± 1/32 ANGULAR ± 1/2°	
NO	REVISION	DATE	BY	SCALE	HG150AW00STC, 150HP 480/3/60, OPEN, WITH CNT DESIGNED BY DSW DATE 7/3/08 DRAWING NO. C 103536DG SCALE TO SCALE SHEET 1 OF 1