



FOR SCHEMATIC SEE DRAWING 25334-4
FOR WIRING SEE DRAWING 25334-5

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS.
CAPACITORS MAXIMUM AMBIENT 50°C
PC BOARD MAX. AMBIENT 40°C.

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

UNIT SPECIFICATIONS:					
KVAR	HARMONIC	VOLT	HZ	PHASE	HP
75	5TH	480	60	3	250
STYLE		WHITE OPEN PANEL			
OPTIONS		MULTI-FEATURE BOARD			
APPROX.WT. LBS.		530			

SYMBOL	TCI PART NUMBER
LR	KDRS2TMOID
TR	KTR75A65HGX1
CAP.1,2,3	KCAP20A6B
CAP.4	KCAP15A6B
XFMR.	23894
Fu1,2,3	13333
Fu4,6	13203
Fu5	13362
CNT	23368
HG2 (MULTI-FEATURE)	20830

TOLERANCES UNLESS AS NOTED			
DECIMAL	FRACTIONAL	ANGULAR	SCALE
.XX ± .03			
.XXX ± .01			
	± 1/32		
		± 1/2°	

2516, CAP1,2,3 WERE 20123	12/20/07	RJC	
CAP 4 WAS 16449	DATE	BY	
NO	REVISION	DATE	BY

TCI	7878 N. 86th STREET MILWAUKEE, WI 53224
HG250AW00XM, HG7, 250HP 480/3/60, MONITOR PACKAGE	
DRG. NO. 102753DG	DATE 09/12/05
SCALE TO FIT	APPROVA C
SHT. 1	OF 1