



| UNIT SPECIFICATIONS: |      |     |                  |    |    |
|----------------------|------|-----|------------------|----|----|
| KVAR HARMONIC        | VOLT | HZ  | PHASE            | HP |    |
| 5                    | 5TH  | 480 | 60               | 3  | 15 |
| ENCLOSURE            |      |     | WHITE OPEN PANEL |    |    |
| APPROX.WT. LBS.      |      |     | 50               |    |    |

| SYMBOL    | TCI PART NUMBER |
|-----------|-----------------|
| LR        | KDRF1T          |
| TR        | KTR5A65HG       |
| CAP.      | 16447           |
| Fu1, 2, 3 | 15752           |

PB—POWER INPUT BLOCK:  
 WIRE RANGE—#18 TO #4 AWG.  
 TIGHTENING TORQUE 20 IN-LB.

GROUND LUG:  
 WIRE RANGE—1/0 TO #14 AWG.  
 TIGHTENING TORQUE 200 IN-LB.

SEE 25077 FOR SCHEMATIC

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS. CAPACITORS MAXIMUM AMBIENT 50°C

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

|    |                    |          |     |                            |  |
|----|--------------------|----------|-----|----------------------------|--|
|    |                    |          |     | TOLERANCES EXCEPT AS NOTED | 7878 N. 86th STREET MILWAUKEE, WI 53224<br><b>HG15AW00ST, HG7 STANDARD 15 HP, 480/3/60, OPEN</b> |
|    |                    |          |     | DECIMAL                    |  |
|    |                    |          |     | .XX ± .03<br>.XXX ± .01    |  |
|    |                    |          |     | FRACTIONAL ± 1/32          |  |
| △  | REMOVE POWER BLOCK | 02/21/06 | DSW | ANGULAR ± 1/2°             | DRN BY DSW DATE 03/02/05<br>SCALE TO FIT APPROV. B DVG NL 102537DG<br>SHT.1 of 1                 |
| NO | REVISION           | DATE     | BY  |                            |  |