



UNIT SPECIFICATIONS:					
KVAR	HARMONIC	VOLT	HZ	PHASE	HP
3	5TH	480	60	3	7.5
ENCLOSURE		WHITE OPEN PANEL			
APPROX.WT. LBS.		40			

SYMBOL	TCI PART NUMBER
LR	KDRC1T
TR	KTR3A65HG
CAP.	16446
Fu1, 2, 3	11262

PB—POWER INPUT BLOCK:  
 WIRE RANGE—#18 TO #4 AWG.  
 TIGHTENING TORQUE 20 IN—LB.

GROUND LUG:  
 WIRE RANGE—1/0 TO #14 AWG.  
 TIGHTENING TORQUE 200 IN—LB.

SEE 25077 FOR SCHEMATIC

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS. CAPACITORS MAXIMUM AMBIENT 50°C

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

TOLERANCES EXCEPT AS NOTED				TCI 7878 N. 86th STREET MILWAUKEE, WI 53224
△ MOVED POWER BLOCK	2/21/06	DSW		DRN BY DSW DATE 03/02/05 DWG. NO. B 102535DG
NO REVISION	DATE	BY		SCALE TO FIT APPRVD. SHT. 1 of 1