


CATALOG NO	VOLTAGE	NEC MOTOR HP	NEC MOTOR CURRENT	WATTS LOSS	APPROX. WEIGHT-LBS	TORQUE (LB-IN)
KDRC1LC2	480	40	52.0	114	21	20
KDRC3HC2	480	20	27.0	108	21	20
KDRC1HC2	480	25	34.0	112	21	20
KDRC1PC2	480	40	52.0	NOTE 1	21	20
KDRC3IPC2	575	50	52.0	NOTE 1	21	20

NOTE 1: WATTS LOSS WILL VARY DUE TO FUNDAMENTAL FREQUENCY, CARRIER FREQUENCY AND OTHER SYSTEM CHARACTERISTICS. KDR DRIVE REACTORS COMPLY WITH THE THERMAL AND ALTITUDE STANDARDS SET FORTH BY NEMA ST20-1992.

NOTE: A1, A2, B1, B2, C1, C2, MARKINGS ON COIL AND TERMINAL BLOCK FOR REFERENCE ONLY.

Block Wire Range: #18 to #4 AWG Solid or Stranded, Copper
Tightening Torque: 20 LB-IN



ENCLOSURE LABEL PLACED ON FRONT COVER.

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

				TOLERANCES EXCEPT AS NOTED	TCI 7878 N. 86th STREET MILWAUKEE, WI 53224		
				DECIMAL	KDR ASSEMBLY, "C" FRAME "C2" ENCL., INPUT & OUTPUT		
				.XX ± .03			
				.XXX ± .01			
2604 MARK REF	4/17/09	DSW	FRACTIONAL ± 1/32	DRN BY RJC DATE 5/29/01 DWG. NO. B KDR-3DG			
A 2235 REACTOR MTG	09/15/03	DSW	ANGULAR ± 1/2°	SCALE 3/8"=1" APPRVD. B SHT.1 OF 1			
NO	REVISION	DATE	BY				