

PERFORMANCE AND PROTECTION FOR DRIVES.

Trans-Coil, Inc.
Milwaukee, WI
www.transcoil.com
800-524-5252


KLCUL Output Filter
KLCUL2A1
3PH, 50/60Hz, 600V Max, 2A Max
Dwg #: 101201DG Schematics #: 25389
Enclosure type: 1

UL LISTED
NO. 606, 60, 405

DATE CODE


TCI TRANS-COIL, INC.
MILWAUKEE, WISCONSIN
(414) 387-4488
FAX (414) 387-4484

dV/dt GUARD
KLC OUTPUT FILTER







SEE: KLC/KLCUL INSTALLATION GUIDE.
TCI# 25389

NOTE: INSTALLATION GUIDE MUST
BE SHIPPED WITH EACH UNIT.



RECOMMENDED CONDUIT
ENTRANCE AREA -
TOP, LOWER LEFT SIDE,
AND LOWER RIGHT SIDE.

CATALOG NO.	KLCUL2A1
VOLTS	480
AMPS	2
KLR PART NO.	KLR2BTB
KLR BOARD NO.	24680
APPROX. WT.-LBS	15
BLOCK WIRE RANGE FOR REACTOR AND TIGHTENING TORQUE.	#12-#18 AWG 10 LB-IN



NOTE: CABINET
MATERIAL: #16 GA STEEL
FINISH: COLOR, BEIGE.

CUSTOMER IS RESPONSIBLE FOR INSTALLATION
TO MEET ALL NATIONAL AND LOCAL ELECTRICAL
CODES

				TOLERANCES (EXCEPT AS NOTED)
				DECIMAL
H	2455 UPDATE SCHEM.	10/2/06	DSW	.XX ±.03
G	2413, REMOVE GRD.	02/14/06	DSW	.XXX ±.01
F	2326, BOARD UPDATE	11/16/04	DSW	FRACTIONAL ± 1/32
E	2314, UPDATE LOUVERS	08/24/04	DSW	ANGULAR ± 1/2°
NO	REVISION	DATE	BY	

TCI 7878 N. 86th STREET
MILWAUKEE, WI 53224

KLCUL ENCLOSED OUTPUT
FILTER, 480V, KLCUL2A1

DRN. BY DSW DATE 04-04-08 DWG. NO. 101201DG
SCALE 3/16"=1" APPRD. B SH. 1 OF 1