





NOTE: A1, A2, B1, B2, C1, C2, MARKINGS ON TERMINAL BLOCK. FOR REFERENCE ONLY.

CATALOG NO	VOLTS(V)	%MH±10%	AMPS(A)	APPROX WT-LBS	TORQUE(LB-IN)
KLR6CTB	24.00	6.13	6	7	10
KLR6ETB	28.75	7.34	6	7	10
KLR8CTB	24.0	4.59	8	7	10
KLR8DTB	17.25	3.30	8	7	10
KLR8ETB	28.75	5.50	8	7	10
KLR12ATB	14.4	1.84	12	7	10
KLR12CTB	24.0	3.063	12	8	10
KLR12DTB	17.25	2.20	12	7	10



				TOLERANCES EXCEPT AS NOTED	TCI 7878 N. 86th STREET MILWAUKEE, WI 53224					
				DECIMAL						
				.XX ± .03						
				.XXX ± .01						
				FRACTIONAL ± 1/32						
				ANGULAR ± 1/2°						
NO	2235, MOUNTING CHG	06/02/03	DSW	DRN BY	RJC	DATE	05/18/95	DWG NO	B	KLR-19DG
REVISION				SCALE	TO FIT	APPRVD.		SHT. 1 of 1		

SINE-GUARD REACTOR  
KLR TB'S (FRAME B)