



FOR SCHEMATIC SEE DRAWING P/N 24281-11

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF COMPONENTS IN CUSTOMERS ASSEMBLY.

CUSTOMER IS RESPONSIBLE FOR PROPER INSTALLATION OF ASSEMBLY IN ACCORDANCE WITH LOCAL AND NATIONAL CODES.

CAT# KMG10C  
 HP 7.5 FLA 10  
 VOLTS 575/600V  
 60 HZ 3 PH

DWG # 102023DG  
 OPEN PANEL  
 DATE

CAT# KMG10C

GROUND LUG  
 WIRE RANGE: 1/0-14 AWG  
 TORQUE: 200 LB-IN

LINE CONNECTIONS  
 WIRE RANGE: 1 AWG THRU 4 AWG 35 LB-IN  
 6 AWG THRU 14 AWG 30 LB-IN  
 16 AWG THRU 22 AWG 25 LB-IN

				TOLERANCES (EXCEPT AS NOTED)	 7878 N. 86th STREET MILWAUKEE, WI 53224
				DECIMAL	
				.XX ±.01 .XXX±.005	
				FRACTIONAL ± 1/32	
				ANGULAR ± 1/2°	DRN BY RJC    DATE 1/6/03    DWG. NO. 102023DG SCALE FULL    APRVD.    B
NO	REVISION	DATE	BY		SHT. 1 of 1