

CAT# KMG130C  
 125 FLA 130  
 VOLTS 575/600V  
 60 HZ 3 PH

DWG # 102034DG  
 OPEN PANEL  
 DATE

FOR SCHEMATIC SEE DRAWING P/N 24281-13


CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF COMPONENTS IN CUSTOMERS ASSEMBLY

CUSTOMER IS RESPONSIBLE FOR PROPER INSTALLATION OF ASSEMBLY IN ACCORDANCE WITH LOCAL AND NATIONAL CODES.

CAT# KMG130C

GROUND LUG  
 WIRE RANGE: 2/0-#6 AWG  
 TORQUE: 120 LB-IN

LINE CONNECTIONS  
 WIRE RANGE: 2/0-#6 AWG  
 TORQUE: 120 LB-IN

				TOLERANCES (EXCEPT AS NOTED)	 7878 N. 86th STREET MILWAUKEE, WI 53224
				DECIMAL	
				.XX ±.01 .XXX±.005	
				FRACTIONAL ± 1/32	
				ANGULAR ± 1/2°	DRN BY RJC
NO	REVISION	DATE	BY		DATE 1/26/03
					APRVD.
					DWG. NO. B 102034DG
					SHT. 1 of 1