

FOR SCHEMATIC SEE DRAWING P/N 24281-13

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF COMPONENTS IN CUSTOMERS ASSEMBLY.

CUSTOMER IS RESPONSIBLE FOR PROPER INSTALLATION OF ASSEMBLY IN ACCORDANCE WITH LOCAL AND NATIONAL CODES.


CAT# KMG160C

CAT# KMG160C
 HP 150 FLA 160
 VOLTS 575/600V
 60 HZ 3 PH

DWG # 102035DG
 OPEN PANEL
 DATE

GROUND LUG
 WIRE RANGE: 250MCM-#6 AWG
 TORQUE: 275 LB-IN

LINE CONNECTIONS
 WIRE RANGE: 250MCM-#6 AWG
 TORQUE: 275 LB-IN

				TOLERANCES (EXCEPT AS NOTED)	 7878 N. 86th STREET MILWAUKEE, WI 53224
				DECIMAL .XX ± .01 .XXX ± .005	
				FRACTIONAL ± 1/32	SINEWAVE FILTER, OPEN 150 HP, 160 AMP, 600 V.
				ANGULAR ± 1/2°	
C	update inductor	10/10/08	ds	W	DRN. BY: RJC SCALE: --
NO	REVISION	DATE	BY		DATE: 1/26/03 APRVD:
					DWG. NO. B 102035DG SHT.1 OF 1