

FOR SCHEMATIC SEE DRAWING P/N 24281-12

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF COMPONENTS IN CUSTOMERS ASSEMBLY.

CUSTOMER IS RESPONSIBLE FOR PROPER INSTALLATION OF ASSEMBLY IN ACCORDANCE WITH LOCAL AND NATIONAL CODES.


CAT# KMG45C  
 HP 40 FLA 45  
 VOLTS 575/600V  
 60 HZ 3 PH

DWG # 102029DG  
 OPEN PANEL  
 DATE

CAT# KMG45C

GROUND LUG  
 WIRE RANGE: 1/0-14 AWG  
 TORQUE: 200 LB-IN

LINE CONNECTIONS  
 WIRE RANGE: 1 AWG THRU 4 AWG 35 LB-IN  
 6 AWG THRU 14 AWG 30 LB-IN  
 16 AWG THRU 22 AWG 25 LB-IN

				TOLERANCES (EXCEPT AS NOTED)		 7878 N. 86th STREET MILWAUKEE, WI 53224	
				DECIMAL			
				.XX ± .01		SINEWAVE FILTER, OPEN 40 HP, 45 AMP, 600 V.	
				.XXX ± .005			
				FRACTIONAL		DRN BY RJC	
				± 1/32		DATE 1/26/03	
				ANGULAR		APRVD. B	
				± 1/2°		DWG. NO. 102029DG	
NO.	REVISION	DATE	BY	SCALE --		SHT. 1 of 1	