

FOR SCHEMATIC SEE DRAWING P/N 24281-1
 CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF COMPONENTS IN CUSTOMERS ASSEMBLY.
 CUSTOMER IS RESPONSIBLE FOR PROPER INSTALLATION OF ASSEMBLY IN ACCORDANCE WITH LOCAL AND NATIONAL CODES.


CAT# KMG8A

CAT# KMG8A
 HP 5 FLA 8
 VOLTS 460/480V
 60 HZ 3 PH

DWG # 101978DG
 OPEN PANEL
 DATE

GROUND LUG
 WIRE RANGE: 1/0-14 AWG
 TORQUE: 200 LB-IN

LINE CONNECTIONS
 WIRE RANGE: 1 AWG THRU 4 AWG 35 LB-IN
 6 AWG THRU 14 AWG 30 LB-IN
 16 AWG THRU 22 AWG 25 LB-IN

				TOLERANCES (EXCEPT AS NOTED)		 7878 N. 86th STREET MILWAUKEE, WI 53224	
				DECIMAL			
				.XX ± .01		SINEWAVE FILTER, OPEN 5 HP, 8 AMP, 480 V.	
				.XXX ± .005			
				FRACTIONAL		DRN BY RJC	
				± 1/32		DATE 1/6/03	
				ANGULAR		APRVD. B	
				± 1/2°		DWG. NO. 101978DG SHT. 1 of 1	
NO.	REVISION	DATE	BY			SCALE FULL	