



CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

TOLERANCES EXCEPT AS NOTED		TCI 7878 N. 86th STREET MILWAUKEE, WI 53224
DECIMAL	.XX ± .03 .XXX ± .010	
FRACTIONAL	± 1/16	KLR SERIES 3 PH REACTOR 690V (FRAME S) ENCLOSED
ANGULAR	± 1/2°	
DRN BY	DSW	DATE 03/30/07
SCALE	TO FIT	APPR'VD
REV. NO.		DATE
BY		BY

690V	NEC MOTOR HP	CATALOG NO	__AMPS(A)	APPROX WT-LBS	WATTS LOSS	TERMINAL HOLE SIZE
5% Z	350	KLR360ECB5V	360	210	463	.56 DIA HOLE