


PB-POWER INPUT BLOCK:
 WIRE RANGE-1 AWG, (7 TO 9 STRANDS ONLY).
 2 AWG TO 22 AWG.
 TIGHTENING TORQUE: 1 AWG THRU 4 AWG, 35 IN-LB MAX.
 6 AWG THRU 14 AWG, 30 IN-LB MAX.
 16 AWG THRU 22 AWG, 25 IN-LB MAX.



NOTE: THIS IS A STANDARD HEIGHT DISPLAY LIGHT BRACKET FOR USE WITH STANDARD ENCLOSED UNITS OR OPEN PANELS

SEE 21579-1 FOR WIRING CONNECTIONS
 SEE 21725-1 FOR SCHEMATIC

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS.
 CAPACITORS MAXIMUM AMBIENT 50°C


CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

UNIT SPECIFICATIONS:					
KVAR HARMONIC	VOLT	HZ	PHASE	HP	
15	5TH	480	60	3	40
ENCLOSURE		WHITE OPEN PANEL			
		INDICATOR LIGHTS			
APPROX.WT. LBS.		65			

SYMBOL	TCI PART NUMBER
LR	KLR55CTB
TR	KTR15A65
CAP	16449
XFMR.	23891
Fu1;2;3	11307
Fu4,6	13180
Fu5	13364
CNT	23073

TRAP FILTER FUSING Fu1;2;3

XFMR. Fu4,6 Fu5

				TOLERANCES (EXCEPT AS NOTED) DECIMAL	 7878 N. 86th STREET MILWAUKEE, WI 53224
				.XX ± .03 .XXX ± .01	
B	2152, ADD XFMR FBLK	02/18/02	DSW	FRACTIONAL ± 1/16	TCI, KH015A6L5B40, OPEN HARMONIC FILTER DRN BY DSW DATE 03/11/99 DWG. NO. B 100468DG SCALE 1/8"=1' APRVD. SHT.1 of 1
A	SEE ECO #1951	3/30/2000	BW	ANGULAR ± 1/2°	
NO	REVISION	DATE	BY		