

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF COMPONENTS IN CUSTOMERS ASSEMBLY.

CUSTOMER IS RESPONSIBLE FOR PROPER INSTALLATION OF ASSEMBLY IN ACCORDANCE WITH LOCAL AND NATIONAL CODES.


CAT# KMG16A  
 HP 10 FLA 16  
 VOLTS 460/480V  
 60 HZ 3 PH

DWG # 101980DG  
 OPEN PANEL  
 DATE

CAT# KMG16A

GROUND LUG  
 WIRE RANGE: 1/0-14 AWG  
 TORQUE: 200 LB-IN

LINE CONNECTIONS  
 WIRE RANGE: 1 AWG THRU 4 AWG 35 LB-IN  
 6 AWG THRU 14 AWG 30 LB-IN  
 16 AWG THRU 22 AWG 25 LB-IN

				TOLERANCES (EXCEPT AS NOTED)		 7878 N. 86th STREET MILWAUKEE, WI 53224	
				DECIMAL			
				.XX ± .01		SINEWAVE FILTER, OPEN 10 HP, 16 AMP, 480 V.	
				.XXX ± .005			
				FRACTIONAL		DRN BY RJC DATE 1/6/03 DWG. NO. 101980DG SCALE FULL APRVD. B	
				± 1/32			
				ANGULAR		SHT. 1 of 1	
				± 1/2°			
NO.	REVISION	DATE	BY				