

FOR SCHEMATIC SEE DRAWING P/N 24281-2

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF COMPONENTS IN CUSTOMERS ASSEMBLY.

CUSTOMER IS RESPONSIBLE FOR PROPER INSTALLATION OF ASSEMBLY IN ACCORDANCE WITH LOCAL AND NATIONAL CODES.


CAT# KMG23A

CAT# KMG23A
 HP 15 FLA 23
 VOLTS 460/480V
 60 HZ 3 PH

DWG # 101981DG
 OPEN PANEL
 DATE

GROUND LUG
 WIRE RANGE: 1/0-14 AWG
 TORQUE: 200 LB-IN

LINE CONNECTIONS
 WIRE RANGE: 1 AWG THRU 4 AWG 35 LB-IN
 6 AWG THRU 14 AWG 30 LB-IN
 16 AWG THRU 22 AWG 25 LB-IN

				TOLERANCES (EXCEPT AS NOTED)	 7878 N. 86th STREET MILWAUKEE, WI 53224
				DECIMAL	
				.XX ± .01 .XXX ± .005	
				FRACTIONAL ± 1/32	
				ANGULAR ± 1/2°	DRN BY RJC
					DATE 1/6/03
					APRVD.
					DWG. NO. 101981DG
					SHT. 1 of 1
NO.	REVISION	DATE	BY		