

CAT# KMG750A
 HP 600 FLA 750
 VOLTS 460/480V
 60 HZ 3 PH


DWG # 101998DG
 OPEN PANEL
 DATE

FOR SCHEMATIC SEE DRAWING P/N 24281-5
 CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF COMPONENTS IN CUSTOMERS ASSEMBLY.
 CUSTOMER IS RESPONSIBLE FOR PROPER INSTALLATION OF ASSEMBLY IN ACCORDANCE WITH LOCAL AND NATIONAL CODES.

CAT# KMG750A

GROUND LUG
 WIRE RANGE: (3)600MCM- #2 AWG
 TORQUE: 375 LB-IN

LINE CONNECTIONS
 WIRE RANGE: (3)600MCM- #2 AWG
 TORQUE: 375 LB-IN

				TOLERANCES (EXCEPT AS NOTED)		 7878 N. 86th STREET MILWAUKEE, WI 53224	
				DECIMAL			
				.XX ±.01		SINEWAVE FILTER-OPEN 600 HP, 750 AMP, 480 V.	
				.XXX±.005			
				FRACTIONAL		DRN BY RJC	
				± 1/32		DATE 1/6/03	
				ANGULAR		APRVD. B	
				± 1/2°		DWG. NO. 101998DG	
NO	REVISION	DATE	BY	SCALE --	SHT. 1 OF 1		