








Alternate Rain Hood Construction.

Unit Specifications					
kVar	Harmonic	Volt	HZ.	Phase	HP
5	5TH	480	60	3	30

TCI Part Number	Option	Weight	Schematic
HGL0030AW3S0000	Standard	195lbs	30586-1
HGL0030AW3C0000	Contactorm	205lbs	30586

See IOM Manual For Wire Range And Tightening Torque.



CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.
NOTE: USE ONLY HUBS OR FITTINGS THAT COMPLY WITH UL514B FOR TYPE 3R ENCLOSURES

Material(s) Shall be RoHS Compliant

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREDJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.				TOLERANCES (EXCEPT AS NOTED) DECIMAL	TCI W132 N10611 GRANT DRIVE GERMANTOWN, WI 53022
				.XX +/- .25	
				.XXX +/- .12	FRACTIONAL
				+/- 1/16	ANGULAR
A	AS DESIGNED	8/15/17	DSW	SCALE 1/8	DRN. BY DSW DATE 8/15/17 DWG. No. 107200DG
NO	REVISION	DATE	BY	SCALE +/- 1	APRVD. SHEET 1 OF 1