









(Customer Connections)
Markings On Pressure
Terminals
For Reference Only.



208/240 Rated Voltage, 600 Max Voltage, High Z, Impedance.							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Attached Lug Kit	Losses (W)
KDULRH24H	50	143	143	143	32	SLK21	201
KDRULH23H	60	169	169	103	38	SLK21	220

208/240 Rated Voltage, 600 Max Voltage, Low Z, Impedance.							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Attached Lug Kit	Losses (W)
KDULRH22L	60	169	180	62.4	30	SLK21	209

480 Rated Voltage, 600 Max Voltage, Low Z, Impedance.							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Attached Lug Kit	Losses (W)
KDULRH3L	100	124	150	152	36	SLK21	225
KDRULH2L	125	156	165	117	36	SLK21	254
KDRULH1L	150	180	185	103	36	SLK21	299



- Note:
1. UL file number: cULus Listed File E116124.
 2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 3. For Terminal Torques And Wire Size See, KDR IOM Manual, Part Number 30895
 4. NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
 5. Material(s) Shall be RoHS Compliant
 6. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

DIMENSIONS IN INCHES (EXCEPT AS NOTED) TOLERANCES (EXCEPT AS NOTED) DECIMAL XX ± .25 XXX ± .10 FRACTIONAL ± 1/32 ANGULAR ± 1°		THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIANT INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIANT INC. AND ITS SUBSIDIARIES.		F 6550 Add Lift Rings		01/30/24 DSW		DSW		W132N10611 Grant Drive Germantown, WI 53022 © 2024 Alliant Inc.	
E 6535 Termination chg		D 6420 Remove H2H		C 6394 Remove H1P, H31P		B 5937 Add Lift Rings		A Combined Drawings		KDRUL, H Frame Flag Termination Inductor Drawing	
NO ECO		REVISION		DATE		BY		1/2		107589-2DG	
										SHT. 1 OF 1	