


480 Rated Voltage, 600 Max Voltage, Low Z, Impedance.							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULL3LE01	600	720	750	26	475	510	SLK15

575 Rated Voltage, 600 Max Voltage, Low Z, Impedance.							
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULL43LE01	700	672	675	34	598	590	SLK15

Ground Lug.
See IOM Manual, Part# 30895
Table 2S350, Wire Size And Torque.

Suggested Customer Wire Entrance
Bottom Of Enclosure.
See Note: 5
(Non Removeable Panel)

Suggested Customer Entrance
Either Side Of Enclosure.
See Note: 5
(Non Removeable Panel)



- Note:
1. UL file number: cULus Listed File E116124.
 2. KDR Drive Inductors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 3. For Terminal Torques And Wire Size See, KDR IOM Manual, Part Number 30895
 4. Material(s) Shall be RoHS Compliant
 5. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

DIMENSIONS IN INCHES (EXCEPT AS NOTED) TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10 FRACTIONAL ± 1/32 ANGULAR ± 1°		THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIANT INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIANT INC. AND ITS SUBSIDIARIES.		DESIGNED BY DSW	DATE 03/22/18			W132N10611 Grant Drive Germantown, WI 53022 © 2026 Alliant Inc.
C	7551	Update Enclosure	06/17/26	DSW	KDRULL3LE01, KDRULL43LE01 Enclosed Type 1			
B	5510	Inductor Terminal Flag updated	02/15/21	DSW				
A		As Designed	03/22/18	DSW				
NO	ECO	REVISION	DATE	BY	SCALE 1/9	DWG. NO. 107614-8DG	SIZE C	SHT. 1 OF 1