



Wire Range: 1- 4 AWG. Torque : 35 IN-LBS (3.95 Nm)
 6- 14 AWG. Torque : 30 IN-LBS (3.39 Nm)
 16- 20 AWG. Torque : 25 IN-LBS (2.28 Nm)
 22 AWG. Torque : 20 IN-LBS (2.26 Nm)



Markings On Terminal Block For Reference Only.

Suggested Customer Entrance Either Side Of Enclosure.
See Note: 5
(Non Removeable Panel)



See Website for Electrical Information, Part Numbers Listed below.
 KDRF28H, KDR4H, KDRF1H, KDRF2L
 KDRF4L, KDRF44H, KDRF45H, KDRF46L
 KDRF47L, KDRF1P, KDRF2P, KDRF31P
 KDRF32P.

- Notes:
1. UL file number: cULus Listed File E116124.
 2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 3. KDR IOM Manual Part Number 30895
 4. Material(s) Shall be RoHS Compliant
 5. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

DIMENSIONS IN INCHES (EXCEPT AS NOTED) TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .03 .XXX ± .010 FRACTIONAL ± 1/32 ANGULAR ± 1°		THE INFORMATION AND DESIGN CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIENT INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIENT INC. AND ITS SUBSIDIARIES.		DESIGNED BY	DSW	DATE	4/24/18	 W132N10611 Grant Drive Germantown, WI 53022 © 2025 Allient Inc.		
E	7309	Remove Table Information	12/1/25	DSW	KDR F Frame, Terminal Block Type 3R, Inductor Drawing					
D	66688	FIH, 70A to 72A	6/7/24	DSW						
C	5841	FIH, 85A to 70A	1/27/22	DSW						
NO	ECO	REVISION	DATE	BY						
SCALE		1:4.5		DEN. NO.		107667-1DG		SIZE	C	SHT. 1 OF 1