

4

3

2

1

Capacitor, 5kVar, 600V, 60Hz
Dry Version, Spring Clamp, Vishay.
3 x 12.2uF Delta Connection

Approx Weight: 1.32 LBS



1.96 ± 0.039

2.66 ± 0.039




Wire Range: 14 AWG To 4 AWG
Strip Length: 0.71 IN.
Wire Insulation Insertion Depth: 0.315 IN.
Maximum Ferrule Dimensions: Rectangular 0.299 IN Wide
By 0.236 IN Thick, Long Dimension Horizontal.

Open Lever to Insert Wire
Release or Close Lever After Wire Is Inserted to Clamp Wire
Lever Is Designed for at Least 10 Operating Cycles.
Continuous Use Can Result in Excessive Wear.



**Warning: Bleeder Resistor Must Be Installed
In Every Capacitor
Capacitor Voltage Will Not Discharge After
Switching Power Off Without Bleeder Resistor Installed.**

Press Orange Plate Marked "PUSH" To Insert Resistor
Leads Into Capacitor Terminal Block.
Body Of Resistor Will Be Flush With Terminal Block.



Note: Bleeder Resistor Color May Vary.

Warning

After switching off the power, always allow 5 minutes for the capacitors in the filter and in the drive to discharge before working on the filter, the drive, the motor, or the connecting wiring. It is a good idea to check with a voltmeter to make sure that all sources of power have been disconnected and that all capacitors have discharged before beginning work.

Material(s) Shall be RoHS Compliant
Material(s) shall meet REACH requirements
Dimensions are in inches unless otherwise specified.

TOLERANCES (INCHES AND MILLIMETERS)		THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE THE PROPRIETARY PROPERTY OF ALLENENT INC. AND ITS SUBSIDIARIES. THIS DRAWING DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLENENT INC. AND ITS SUBSIDIARIES.		DRAWN BY DSW		DATE 12/19/24	
DECIMAL	FRAC.	ANGULAR	NO. ECO	REVISION	DATE	SCALE	DRN. NO.
.XX ± .06		A	As Drawn	12/19/24	DSW	1:13	32816
.XXX ± .03					BY		

Cap, 5kVar, 600, 60Hz
Dry, Spring Clamp, Vishay

W132N10611 Grant Drive
Germantown, WI 53022
© 2024 Allenent Inc.

4

3

2

1

C

A

D

C

B

A

C

SHT.1 OF 1