



UNIT SPECIFICATIONS:					
KVAR	HARMONIC	VOLT	HZ	PHASE	HP
40	5TH	600	60	3	125
ENCLOSURE		WHITE OPEN PANEL			
APPROX.WT. LBS.		220			

SYMBOL	TCI PART NUMBER
LR	KDRL41T
TR	KTR40C65HG
CAP1, CAP2.	KCAP20C6B
Fu1, 2, 3	19061

CUSTOMER CONNECTIONS
 WIRE RANGE- 250MCM-6
 TIGHTENING TORQUE 275 IN-LB.

GROUND LUG:
 WIRE RANGE- 250MCM-6
 TIGHTENING TORQUE 275 IN-LB.

SEE 25115 FOR SCHEMATIC

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS.
 CAPACITORS MAXIMUM AMBIENT 50°C

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

		TOLERANCES (EXCEPT AS NOTED)		7878 N. 86th STREET MILWAUKEE, WI 53224	
		DECIMAL			
		.XX ± .03		HG125CW00ST HG7 STANDARD 125HP, 600/3/60 OPEN	
		.XXX ± .01			
		FRACTIONAL		DRN BY DSW DATE 03/11/05 DWG. NO. 102492DG SCALE TO FIT APRVD. C	
		± 1/32			
2516, CAP WAS 18612	1/2/08	RJC	BY		
NO	REVISION	DATE	BY		