


UNIT SPECIFICATIONS:					
KVAR HARMONIC	VOLT	HZ	PHASE	HP	
45	5TH	480	60	3	150
ENCLOSURE	WHITE OPEN PANEL				
APPROX.WT. LBS.	265				

SYMBOL	TCI PART NUMBER
LR	KDRL2T
TR	KTR45A65HG
CAP.1, CAP.2 (20 KVAR)	KCAP20A6B
CAP.3 (5 KVAR)	KCAP5A6A
XFMR.	23891
Fu1;2;3	11077
Fu4,6	21270
Fu5	13364
CNT	19246



SEE DWG# 26690 FOR SCHEMATIC

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS. CAPACITORS MAXIMUM AMBIENT 50°C.

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

				TOLERANCES (EXCEPT AS NOTED)	TCI 7878 N. 86th STREET MILWAUKEE, WI 53224
				DECIMAL	
				.XX ± .03	HG150AW00STC, 150HP 480/3/60, OPEN, WITH CNT
				.XXX ± .01	
				FRACTIONAL	DRN BY DSW DATE 7/3/08 DWG. NO. 103536DG
				± 1/32	
B	REVISED LAYOUT	12/20/11	DSW	ANGULAR	SCALE TO SCALE
NO	REVISION	DATE	BY	± 1/2°	