



UNIT SPECIFICATIONS:					
KVAR	HARMONIC	VOLT	HZ	PHASE	HP
5	5TH	600	60	3	15
ENCLOSURE		WHITE OPEN PANEL			
APPROX.WT. LBS.		40			

SYMBOL	TCI PART NUMBER
LR	KDRF41T
TR	KTR5C65HG
CAP.	KCAP5C6A
Fu1, 2, 3	11262

PB-POWER INPUT BLOCK:
 WIRE RANGE-#18 TO #4 AWG.
 TIGHTENING TORQUE 20 IN-LB.

GROUND LUG:
 WIRE RANGE TIGHTENING TORQUE.
 1/0-3 AWG. 50 IN-LBS
 4-6 AWG. 45 IN-LBS
 8 AWG. 40 IN-LBS
 10-14 AWG. 35 IN-LBS

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS. CAPACITORS MAXIMUM AMBIENT 50°C

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

SEE 25114 FOR SCHEMATIC

NO	REVISION	DATE	BY	TOLERANCES (EXCEPT AS NOTED)
B	2516, CAP WAS 17815	1/2/08	RJC	DECIMAL .XX ± .03 .XXX ± .01
A	MOVED POWER BLOCK	2/21/06	DSW	FRACTIONAL ± 1/32
				ANGULAR ± 1/2°

TCI 7878 N. 86th STREET MILWAUKEE, WI 53224

HG15CW00ST, HG7 STANDARD 15HP, 600/3/60, OPEN

DRN. BY	DSW	DATE	03/11/05	DWG. NO.	102474DG
SCALE	TO FIT	APRVD.			B

SHT. 1 OF 1