



UNIT SPECIFICATIONS:					
KVAR HARMONIC	VOLT	HZ	PHASE	HP	
15	5TH	240	60	3	40
ENCLOSURE		WHITE OPEN PANEL			
APPROX.WT. LBS.		100			

HG40BW00ST	
COMPONENTS	
LINE REACTOR LR	X
TRAP REACTOR TR	X
CAPACITOR CAP	X
TRAP FUSING FU1,2,3	X

CUSTOMER CONNECTIONS
 L1 L2 L3 T1 T2 T3
 AND GROUND LUG.

WIRE SIZE (AWG)	RATED TORQUE (IN-LBS)
2/0-3	50
4-6	45
8	40
10-14	35

SEE 25179 FOR SCHEMATIC

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS. CAPACITORS MAXIMUM AMBIENT 50°C

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

				TOLERANCES (EXCEPT AS NOTED)	7878 N. 86th STREET MILWAUKEE, WI 53224
				DECIMAL	
				.XX ± .03	HG40BW00ST, HG7 STANDARD 40 HP, 240/3/60, OPEN
				.XXX ± .01	
				FRACTIONAL ± 1/32	DRN. BY DSW DATE 04/14/05 DWG. NO. 102516DG SCALE TO FIT APPRVD. B
				ANGULAR ± 1/2°	
NO	REVISION	DATE	BY		SHT. 1 OF 1