





UNIT SPECIFICATIONS:						
KVAR	HARMONIC	VOLT	HZ	PHASE	HP	
15	5TH	240	60	3	40	
ENCLOSURE		NEMA 1				
		WITH CONTACTOR				
APPROX.WT. LBS.		155				



HG40BW01STC	
COMPONENTS	
LINE REACTOR LR	X
TRAP REACTOR TR	X
CAPACITOR CAP	X
TRAP FUSING FU1,2,3	X
XFMR	X
XFMR FU4,6	X
XFMR FU5	X
CNT	X

CUSTOMER CONNECTIONS
L1 L2 L3 T1 T2 T3
AND GROUND LUG.

WIRE SIZE (AWG)	RATED TORQUE (IN-LBS)
2/0-3	50
4-6	45
8	40
10-14	35

SEE 26824 FOR SCHEMATIC

CUSTOMER IS RESPONSIBLE FOR INSTALLATION
TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

				TOLERANCES (EXCEPT AS NOTED)	 7878 N. 86th STREET MILWAUKEE, WI 53224
				DECIMAL	
				.XX ± .03	HG40BW01STC, 40HP
				.XXX ± .01	
B	3042 LUG TORQ CHG	2/27/14	BMZ	FRACTIONAL ± 1/32	240/3/60, ENCLOSED, WITH CNT
A	2702 RVSD UL SHIELD	11/2/11	RJC	ANGULAR ± 1/2°	
NO	REVISION	DATE	BY	SCALE TO FIT	DSW DATE 10/15/08 APRVB DWG. NO. 103594DG SHT. 1 OF 1