


SEE DWG# 26689 FOR SCHEMATIC

UNIT SPECIFICATIONS:					
KVAR	HARMONIC	VOLT	HZ	PHASE	HP
15	5TH	480	60	3	50
ENCLOSURE		WHITE OPEN PANEL			
APPROX.WT. LBS.		135			

SYMBOL	TCI PART NUMBER
LR	KDRG1T
TR	KTR15A65HG
CAP. (15 KVAR)	KCAP15A6B
XFMR.	23891
Fu1, 2, 3	11307
Fu4,6	21270
Fu5	13364
CNT	23021

ALTERNATE	TCI PART NUMBER
CAP. (15 KVAR)	KCAP15A6B



CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS. CAPACITORS MAXIMUM AMBIENT 50°C.

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

HOLE TOL. +/- .005

		TOLERANCES (EXCEPT AS NOTED)		7878 N. 86th STREET MILWAUKEE, WI 53224
		DECIMAL		
		.XX ± .03		HG50AW00STC, 50HP 480/3/60, OPEN, WITH CNT
		.XXX ± .01		
		FRACTIONAL		DRN BY DSW DATE 7/1/08 DWG. NO. 103531DG SCALE TO SCALE APPRVD. C
		± 1/32		
ASC CAP CHANGE	7/1/13	MJS	ANGULAR	SHT. 1 OF 1
NO REVISION	DATE	BY	± 1/2°	