









UNIT SPECIFICATIONS:					
KVAR	HARMONIC	VOLT	HZ	PHASE	HP
15	5TH	600	60	3	50
ENCLOSURE		NEMA 1			
OPTIONS		WITH CONTACTOR			
APPROX.WT. LBS.		190			

SYMBOL	HG60CW01STC
LR	X
TR	X
CAP	X
XFMR.	X
Fu1, 2, 3	X
Fu4,6	X
CNT	X

HATCHED AREA(S) ARE SUGGESTED
CUSTOMER WIRE ENTRANCE AND EXIT LOCATIONS
(BOTTOM ENTRANCE ALTERNATE-CONSULT TCI)



SEE DWG# 26878 FOR SCHEMATIC
CUSTOMER IS RESPONSIBLE FOR INSTALLATION
TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

				TOLERANCES (EXCEPT AS NOTED)	 W132 N10611 Grant Drive Germantown, WI. 53022
				DECIMAL	
				.XX ± .25	
				.XXX ± .10	
B	3664, REVISED FUSING	6/21/16	DSW	FRACTIONAL ± 1/16	HG50CW01STC 50HP 600/3/60, ENCLOSED, WITH CNT
A	2702 RVSD UL SHIELD	2/1/12	RJC	ANGULAR ± 1°	
NO	REVISION	DATE	BY	SCALE TO FIT	DRN. BY DSW
					DATE 11/12/08
					APRVD.
					DWG. NO. 103551DG
					SHT.1 of1