
SEE 26824 FOR SCHEMATIC



CUSTOMER CONNECTIONS:
WIRE RANGE-250MCM-6
TIGHTENING TORQUE 275 IN-LB.


GROUND LUG:
WIRE RANGE-250MCM-6
TIGHTENING TORQUE 275 IN-LB.

UNIT SPECIFICATIONS:					
KVAR H	ARMONIC	VOLT	HZ	PHASE	HP
20	5TH	240	60	3	60
ENCLOSURE		WHITE		N PANEL	
		WITH	CON	TACTOR	
APPROX.WT. LBS.		140			

SYMBOL	TCI PART NUMBER
LR	KDRG22T
TR	KTR20B65HG
CAP1, 2 (10 KVAR)	KCAP10B6B
XFMR.	23891
Fu1a;2a;3a	15740
Fu4,6	24073
Fu5	13364
CNT	19245

CUSTOMER IS RESPONSIBLE FOR PROPER COOLING OF FILTER COMPONENTS. CAPACITORS MAXIMUM AMBIENT 50°C.

CUSTOMER IS RESPONSIBLE FOR INSTALLATION
TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.



REVISION

HG60BW00STC, 60HP

240/3/60, OPEN, WITH CNT

DRN. BY DSW DATE 10/10/08 DWG. NO. 103607DG SCALE TO SCALE SHT. 1 OF1

.XXX±.01

± 1/32

FRACTIONAL

ANGULAR ± 1/2°

DATE