





UNIT SPECIFICATIONS:					
KVAR	HARMONIC	VOLT	HZ	PHASE	HP
20	5TH	600	60	3	60
ENCLOSURE		NEMA 1			
APPROX.WT. LBS.		190			

SYMBOL	TCI PART NUMBER
LR	KDRG42T
TR	KTR20C65HG
CAP.	KCAP20C6B
Fu1, 2, 3	22925



RB BLEED RESISTORS ON CAPACITOR TERMINALS

HATCHED AREAS ARE SUGGESTED CUSTOMER WIRE AND EXIT LOCATIONS (BOTTOM ENTRANCE ALTERNATE-CONSULT TCI)



PB-POWER INPUT BLOCK:

2/0 AWG thru 6 AWG 120 IN-LBS. MAX.  
 8 AWG 40 IN-LBS. MAX.  
 10 AWG thru 14 AWG 35 IN-LBS. MAX.

GROUND LUG:  
 WIRE RANGE-1/0 TO #14 AWG.

1/0 AWG thru 2 AWG 50 IN-LBS. MAX.  
 4 AWG thru 6 AWG 45 IN-LBS. MAX.  
 8 AWG 40 IN-LBS. MAX.  
 10 AWG thru 14 AWG 35 IN-LBS. MAX.


TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.

NO	REVISION	DATE	BY	TOLERANCES (EXCEPT AS NOTED):
D	2702 RVSD UL SHIELD	11/21/11	RJC	DECIMAL .XX ±.03
C	UPDATE LAYOUT	8/30/2010	DSW	.XXX±.01
B	2637 PB CHG	10/06/09	DSW	FRACTIONAL ± 1/32
A	2414 UPDATE FBLK	2/01/06	DSW	ANGULAR ± 1/2°
NO	REVISION	DATE	BY	± 1/2°

**TCI**® W132 N10611 Grant Drive  
 Germantown, WI 53022

HG60CW01ST, HG7 STANDARD  
 60HP, 600/3/60, TYPE 1

DRN. BY DSW DATE 3/15/05 DWG. NO. HG60CW01ST  
 SCALE TO FIT SIZE C SHT.1 OF 1



SEE 25114 FOR SCHEMATIC

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

ENCLOSURE NOT SHOWN