


575 Rated Voltage, 600 Max Voltage, High Z, Impedance.								
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Available Lug Kit	Losses (W)	Terminal Hole Size (Inches)
KDRG44HE01	125	125	130	371	121	SLK10	381	0.28



Ground Lug.
See IOM Manual, Part# 30895
Table S2/0, Wire Size And Torque.

Suggested
Customer Wire Entrance
Bottom Of Enclosure.
See Note: 6
(Non Removeable Panel)

Suggested
Customer Entrance
Either Side Of Enclosure.
See Note: 6
(Non Removeable Panel)

(Customer Connections)
Markings On Coils
For Reference Only.

0.50 Dia Mounting Holes
4 Places, (Bottom of Enclosure)


TCL (800) 824-8282 transcoll.com
 TCL, LLC
 Germantown, WI, USA
 transcoll.com
 800-824-8282

KDRL Drive Reactor
 KDR - Motor Amps -
 3PH, 50/60Hz, -V Rated, 600V Max, -A Max
 40C Amb Max, 155C Max, RoHS
 Manual #30895 LUG KIT #SLK-

UL LISTED CE
 100-Cont. Op. Temp

DATE CODE: A1 A2 B1 B2 C1 C2

- Notes:
1. KDR Lug Kits sold separately. Contact TCL.
 2. UL file number: cULus Listed File E116124.
 3. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 4. KDR IOM Manual Part Number 30895
 5. Material(s) Shall be RoHS Compliant
 6. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.



THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.

NO	REVISION	DATE	BY	SCALE	DATE	DRW BY	CHK	DATE	FILE	SHT	OF
C	6575, Inductor Terminal Change	3/8/2024									
B	6400 Remove KDRG3HE01	9/5/2023	DSW								
A	Combined Drawings	3/19/2018	DSW								
NO											

TCL W132N10611 (Rev. 11/16) Germantown, WI 53022 © 2024 TCL, LLC

An Official Motion Group

KDR G Frame, Copper Bus Enclosed
Type 1, Inductor Drawing

DRW BY: DSW DATE: 3/19/2018 FILE: 107610-1DG
 SCALE: 1/5 DRIVE: C/S SHT: OF: 0