


Ground Lug.  
See IOM Manual, Part# 30895  
Table S2/0, Wire Size And Torque.

Suggested  
Customer Wire Entrance  
Bottom Of Enclosure.  
See Note: 6  
(Non Removeable Panel)

Suggested  
Customer Entrance  
Either Side Of Enclosure.  
See Note: 6  
(Non Removeable Panel)



480 Rated Voltage, 600 Max Voltage, Output									
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Available Lug Kit	Terminal Hole Diameter (Inches)	Revision
KDRH1PE3R	100	124	130	80.2	78	115	SLK10	0.28	B

575 Rated Voltage, 600 Max Voltage, Output									
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Available Lug Kit	Terminal Hole Diameter (Inches)	Revision
KDRH31PE3R	125	125	130	146	78	115	SLK10	0.28	B



- Notes:
1. UL file number: cULus Listed File E116124.
  2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
  3. KDR IOM Manual Part Number 30895
  4. NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
  5. Material(s) Shall be RoHS Compliant
  6. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.				TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10				WI132N10611 (Rev 11/16) Greenfield, WI 53022 © 2023 TCI, LLC An Official Motion Systems Company KDR H Frame, Copper Bus, Enclosed Type 3R, Inductor Drawing	
B	6535, TERMINATION TO 32766	1/31/2024	DSW	FRACATIONAL	± 1/32	DRN BY: DSW	DATE: 8/30/2023	107619-5DG	
A	6394-1, busbar to flag	8/30/2023	DSW	ANGULAR	± 1°	SCALE: 1/4.5	DRN BY: DSW	107619-5DG	
NO	REVISION	DATE	BY	± 1°				SHT 1 OF 1	