



(Customer Connections)  
Markings On Coils  
For Reference Only.



480 Rated Voltage, 600 Max Voltage, High Z, Impedance.

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULI2H	100	124	125	252	53	301	SLK10



**TCL** (800) 824-8282 transcoil.com  
 TCI, LLC  
 Germantown, WI, USA  
 transcoil.com  
 800-824-8282


**KDRUL Drive Reactor**  
 KDR - Motor Amps -  
 3PH, 480/600V, -V Rated, 600V Max, -A Max  
 40C Amb Max, 150C Rise, RoHS  
 Manual #30895 LUG KIT #BLK-

UL US LISTED  
 2ND CONT. OP. 2000

DATE CODE A1 A2 B1 C1 C2

Notes:

1. UL file number: cULus Listed File E116124.
2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
3. KDR IOM Manual Part Number 30895
4. Material(s) Shall be RoHS Compliant
5. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.



THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.

NO	REVISION	DATE	BY
1			
2			

TOLERANCES (EXCEPT AS NOTED)  
 DECIMAL  
 .XX ± .25  
 .XXX ± .10  
 FRACTIONAL  
 ± 1/32  
 ANGULAR  
 ± 1°

**TCL** W132N10611 (Rev 11/16)  
 Germantown, WI 53022  
 © 2024 TCI, LLC  
 An Allied Motion Company  
 KDRULI2H  
 100HP, 3 Phase, Open

DESIGN BY: DSW DATE: 2/5/2024 PART: 107535-13DG  
 SCALE: 1/2 DRAWN BY: CSE SHEET 1 OF 1