

208/240 Rated Voltage, 600 Max Voltage, High Z, Impedance.

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULI22H	75	211	220	85.4	52	312	SLK12
KDRULI21H	100	273	275	64.6	52	296	SLK12

208/240 Rated Voltage, 600 Max Voltage, Low Z, Impedance.


Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULI23L	75	211	211	48.8	52	294	SLK12
KDRULI24L	100	273	280	36.8	52	276	SLK12

480 Rated Voltage, 600 Max Voltage, Output

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULI2P	150	180	200	52	51	135	SLK11

575 Rated Voltage, 600 Max Voltage, Output

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDULRI32P	200	192	200	52.9	46	135	SLK11



\* For single phase applications, use coils A and C, Isolate terminals B1 and B2.

**TCI** (800) 824-8282 transcoil.com

TCI, LLC  
Germantown, WI USA.  
transcoil.com  
800-824-8282

KDRUL Drive Reactor  
KDRUL— Motor Amps —  
3PH, 50/60Hz, —V Rated, 600V Max, —A Max  
40C Amb Max, 155C Rise, RoHS  
Term Torque— lb-in

UL LISTED  
and cert. eq. 5110

- Note:
1. UL file number: cULus Listed File E116124.
  2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
  3. For Terminal Torques And Wire Size See, KDR IOM Manual, Part Number 30895
  4. NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
  5. Material(s) Shall be RoHS Compliant
  6. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.

NO.	REVISION	DATE	BY

TOLERANCES (EXCEPT AS NOTED)  
DECIMAL  
XX ± .25  
.XXX ± .10  
FRACTIONAL  
± 1/16  
ANGULAR  
± 1°

**TCI** W132 N10611 Grant Drive  
Germantown, WI 53022

KDRUL I Frame, Copper Bus  
Reactor Drawing

DRN BY: DSW DATE: 2/28/18 107535DG  
SCALE: 1/2 APRVD: SIZE C SHT 4 OF 6