

208/240 Rated Voltage, 600 Max Voltage, High Z, Impedance.

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)
KDRULB25HE01	5	16.7	17	1030	18.4	53
KDRULB26HE01	7 1/2	24.2	26	699	18.4	67

480 Rated Voltage, 600 Max Voltage, High Z, Impedance.

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)
KDRULB2HE01	15	21	27	1690	17.4	133

575 Rated Voltage, 600 Max Voltage, High Z, Impedance.

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)
KDRULB42HE01	7 1/2	9	10	5370	18.4	61
KDRULB43HE01	10	11	11	4340	18.4	70
KDRULB44HE01	15	17	18.5	2630	18.4	73

480 Rated Voltage, 600 Max Voltage, Output

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)
KDRULB1PE01	10	14	16	701	17.4	20

208/240 Rated Voltage, 600 Max Voltage, Low Z, Impedance.






Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)
KDRULB22LE01	5	16.7	19	626	18.4	39
KDRULB23LE01	7 1/2	24.2	25	434	18.4	48

480 Rated Voltage, 600 Max Voltage, Low Z, Impedance.

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)
KDRULB2LE01	15	21	30	912	18.4	65
KDRULB1LE01	20	27	30	694	18.4	79

575 Rated Voltage, 600 Max Voltage, Low Z, Impedance.

Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)
KDRULB45LE01	15	17	19.5	1590	18.4	66
KDRULB44LE01	20	22	24	1280	18.4	71
KDRULB43LE01	25	27	30	883	18.4	77



**TCI** (800) 824-8282 [transcoil.com](http://transcoil.com)

TCI, LLC  
Germanstown, WI, USA  
[transcoil.com](http://transcoil.com)  
800-824-8282

KDRUL Drive Reactor  
KDRUL — Motor Amps —  
3PH, 50/60Hz, —V Rated, 600V Max, —A Max  
40C Amb Max, 135C Rise, RoHS  
Term Torque — B-In

UL LISTED CE

DATE CODE

- Notes:
1. UL file number: cULus Listed File E116124.
  2. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
  3. KDR IOM Manual Part Number 30895
  4. NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
  5. Material(s) Shall be RoHS Compliant
  6. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

TCI, LLC CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL HEREIN DISCLOSED. IT IS SUPPLIED WITHOUT PREJUDICE TO ANY PATENT RIGHTS OF TCI AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN THEREIN WITHOUT WRITTEN PERMISSION FROM TCI.				TOLERANCES (EXCEPT AS NOTED) DECIMAL XX ± .25 .XXX ± .10 FRACTIONAL ± 1/16 ANGULAR ± 1°		W132 N10611 Grant Drive Germanstown, WI 53022 KDRUL B Frame, Terminal Block, Enclosed Type 1, Reactor Drawing DRN BY: DSW DATE: 3/7/18 107542DG SCALE: 1/3 APRVD: SIZE: C SHT. OF 0	
B	4686, TB, Screws Change to 1/8 Hex	5/9/19	DSW				
A	As Designed	3/7/18	DSW				
NO	REVISION	DATE	BY				