


| 575 Rated Voltage, 600 Max Voltage, High Z, Impedance. | | | | | | | | |
|--|-----------------|----------------|------------------|-----------------|--------------|-------------------|-----------------------------|------------|
| Part Number | Horsepower (HP) | Motor Amps (A) | Maximum Amps (A) | Inductance (uH) | Weight (LBS) | Available Lug Kit | Terminal Hole Size (Inches) | Losses (W) |
| KDRG44H | 125 | 125 | 130 | 371 | 65 | SLK10 | 0.34 | 381 |


| 480 Rated Voltage, 600 Max Voltage, High Z, Impedance. | | | | | | | | |
|--|-----------------|----------------|------------------|-----------------|--------------|-------------------|-----------------------------|------------|
| Part Number | Horsepower (HP) | Motor Amps (A) | Maximum Amps (A) | Inductance (uH) | Weight (LBS) | Available Lug Kit | Terminal Hole Size (Inches) | Losses (W) |
| KDRG3H | 125 | 156 | 160 | 209 | 57 | SLK11 | 0.34 | 274 |



TCL (800) 824-8282 transcoll.com

KDRUL Drive Reactor
 KDR- Motor Amps ---
 3PH, 3Ø/60Hz, ---Y Rated, 600V Max, -A Max
 40C Amb Max, 180C Rise, RoHS
 Manual #30895 LUG KIT #SLK---

DATE CODE



- Notes:
1. KDR Lug Kits sold separately. Contact TCI.
 2. For KDRUL Version With Terminal Lugs Attached, See Sheet 2
 3. UL file number: cULus Listed File E116124.
 4. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 5. KDR IOM Manual Part Number 30895
 6. NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
 7. Material(s) Shall be RoHS Compliant
 8. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

| | | | | | | | |
|--|-------------------|---------|-----|--|--|---|--|
| THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. | | | | TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .03 .XXX ± .010 FRACTIONAL ± 1/32 ANGULAR ± 1° | | W132N10611 (Rev 13 Feb 2022) Germantown, WI 53022 © 2022 TCI, LLC An Official Motion Group Company KDR G Frame, Copper Bus Reactor Drawing DWN BY: DSW DATE: 3/15/18 107533DG SCALE: 1/2 DRAWN: JSC SHEET 1 OF 3 | |
| A | Combined Drawings | 3/15/17 | DSW | | | | |
| NO | REVISION | DATE | BY | | | | |