



208/240 Rated Voltage, 600 Max Voltage, Low Z, Impedance.								
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Available Lug Kit	Terminal Hole Diameter (Inches)
KDRH22LE01	60	169	180	62.4	112	209	SLK21	0.28

480 Rated Voltage, 600 Max Voltage, Low Z, Impedance.								
Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Available Lug Kit	Terminal Hole Diameter (Inches)
KDRH1LE01	150	180	185	103	106	299	SLK21	0.28

Ground Lug.
See IOM Manual, Part# 30895
Table S2/0, Wire Size And Torque.

Suggested Customer Wire Entrance Bottom Of Enclosure.
See Note: 6
(Non Removeable Panel)

Suggested Customer Entrance Either Side Of Enclosure.
See Note: 6
(Non Removeable Panel)

TCI (800) 824-8282 transcoil.com

KDRH Drive Reactor
KDR - Motor Amps -
3PH, 50/60Hz, -V Rated, 600V Max, -A Max
40C Amb Max, 135C Rise, RoHS
Manual #30895 LUG KIT #SLK-

UL LISTED CE
300-CANEX, 90, 2000

DATE CODE: A1 B1 C1

- Notes:
- UL file number: cULus Listed File E116124.
 - KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 - KDR IOM Manual Part Number 30895
 - NEC Current For 208/240 Volts, Horsepower Based On 208 Volts.
 - Material(s) Shall be RoHS Compliant
 - Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.				TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10 FRACTIONAL ± 1/32 ANGULAR ± 1°				W132N10611 (Rev 1346) Germantown, WI 53022 © 2023 TCI, LLC An Official Motors Group KDR H Frame, Copper Bus, Enclosed Type 1, Inductor Drawing DWN BY: DSW DATE: 3/21/2018 107611-3DG SCALE: 1/5 DRAWN BY: CJC SHEET 3 OF 4	
B	6535, Inductor terminal Change	1/24/2024	DSW						
A	6394, Update title Block	8/29/2023	DSW						
NO	REVISION	DATE	BY						