







4
Ground Lug.
See IOM Manual, Part# 30895
Table S2/0, Wire Size And Torque.

2
480 Rated Voltage, 600 Max Voltage, High Z, Impedance.


Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Losses (W)	Attached Lug Kit
KDRULI2HE01	100	124	125	252	119	301	SLK10



Suggested Customer Wire Entrance Bottom Of Enclosure. See Note: 7 (Non Removeable Panel)



Markings On Coils For Reference Only.



* For single phase applications, use coils A and C, Isolate terminals B1 and B2.

TCI
TCI, LLC
Germanstown, WV, USA
transcoil.com
800-824-8282

(800) 824-8282 transcoil.com
KDRUL Drive Reactor
KDR- Motor Amps ---
3PH, 50/60Hz, ---V Rated, 600V Max, -A Max
40C Amb Max, 185C Rise, RefHS
Manual #30895 LUG KIT #SLK---

DATE CODE

Suggested Customer Entrance Either Side Of Enclosure. See Note: 7 (Non Removeable Panel)

- Notes:
1. KDR Lug Kits sold separately. Contact TCI.
 2. KDRUL Version With Terminal Lugs Attached
 3. UL file number: cULus Listed File E116124.
 4. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
 5. KDR IOM Manual Part Number 30895
 6. Material(s) Shall be RoHS Compliant
 7. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.				TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .25 .XXX ± .10 FRACTIONAL ± 1/32 ANGULAR ± 1°				W132N10611 (Rev 11/16) Germanstown, WI 53022 © 2023 TCI, LLC KDRULI2HE01 Type 1 Inductor Drawing OWN BY: DSW DATE: 7/27/2023 107612-10DG SCALE: 1/3 DRAWN BY: CJC SHEET 1 OF 1	
NO	REVISION	DATE	BY	NO	DATE	BY	NO		
		7/27/2023	DSW						