








PART #	RATED AMPS	AMPS MAX	APPROX WT-LBS
--------	---------------	-------------	------------------

KDSS4J	68	68	130
--------	----	----	-----

TCL TRANS-COIL, INC. MILWAUKEE, WI WWW.transcoil.com 800-824-8282		PERFORMANCE AND PROTECTION FOR DRIVES. KDR Drive Reactor CATALOG# MOTOR HP AMPs 1PH, 60Hz, 600V Max, [--- A Max] 40C Amb Max, 155C Rise		
DATE CODE				

130A Filter

				TOLERANCES (EXCEPT AS NOTED): DECIMAL .XX ± .03 .XXX ± .01 FRACTIONAL ± 1/32 ANGULAR ± 1/2°	7878 N. 86th STREET MILWAUKEE, WI 53224
				SINGLE PHASE TRAP FILTER REACTOR 68A MAX , 480V (KDSS4J)	
NO	REVISION	DATE	BY	DRN BY DSW SCALE TO FIT	DATE 01/15/2010 APPRVD DWG NO 104163DG SHT. 1 OF 1