


CATALOG NO	VOLTS(V)	__mH±10%	__AMPS(A)	APPROX WT-LBS	TORQUE(LB-IN)
KLR18BTB	7.20	.620	18	10	20
KLR18FTB	8.62	.734	18	10	20
KLR21BTB	7.20	.525	21	10	20
KLR21FTB	8.62	.629	21	10	20
KLR25BTB	7.20	.441	25	10	20
KLR25FTB	8.62	.528	25	10	20
KLR27BTB	7.20	.408	27	10	20
KLR27FTB	8.62	.489	27	10	20
KLR35BTB	7.20	.315	35	11	20
KLR35FTB	8.62	.377	35	11	20
KLR45BTB	7.20	.245	45	11	20
KLR45FTB	8.62	.294	45	11	20

**TCI** Performance and Protection for Drives.

TRANS-COIL, INC  
MILWAUKEE WI  
WWW.transcoil.com  
800-824-8282

**KLR Series Line Reactor**  
CATALOG

3PH, 60Hz, 600V Max,  $\frac{1}{2}$  Amps  
40C Amb Max, 115C Rise



NOTE: A1, A2, B1, B2, C1, C2,  
MARKINGS ON TERMINAL BLOCK.  
FOR REFERENCE ONLY.

Block Wire Range: #18 to #4 AWG Solid or Stranded, Copper  
Tightening Torque: 20 LB-IN

				TOLERANCES EXCEPT AS NOTED	<b>TCI</b> 7878 N. 86th STREET MILWAUKEE, WI 53224
				DECIMAL	
				.XX ± .03 .XXX ± .01	
				FRACTIONAL	DRN BY EL DATE 02/19/94 DWG NO B KLR-4DG
				± 1/32	
2235, MOUNTING CHG		06/06/03	DSW	ANGULAR	SCALE TO FIT
NO	REVISION	DATE	BY	± 1/2°	APPRV. B
					SHT. 1 of 1