



LOCATION FOR CUSTOMERS CONDUIT FITTING (BOTH SIDES)

.203 DIA HOLE (2 PLACES) MARKED "A"

CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

690V	NEC MOTOR HP	CATALOG NO	__AMPS(A)	APPROX WT-LBS	WATTS LOSS	RING TERMINAL HOLE SIZE.
5% Z	15	KLR18ERL3V	18	29	73	.25

NO	REVISION	DATE	BY

TOLERANCES EXCEPT AS NOTED		7878 N. 86th STREET MILWAUKEE, WI 53224
DECIMAL	.XX ±.03	
FRACTIONAL	.XXX ±.010	
	± 1/16	
		KLR SERIES 3 PH REACTOR 690V (FRAME E) ENCLOSED
		DRN BY DSW DATE 03/30/07 DWG NO. KLR18ERL3V/DG
		SCALE TO FIT APPR'D C SHI.1 OF 1