



KEYSLOT FOR #10 SCREW
(2 PLACES)

COVER IN PLACE

LOCATION FOR CUSTOMERS
CONDUIT FITTING
(BOTH SIDES)

.203 DIA HOLE
(2 PLACES) MARKED "A"

CUSTOMER IS RESPONSIBLE FOR INSTALLATION
TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

| 690V | NEC MOTOR HP | CATALOG NO | __AMPS(A) | APPROX WT-LBS | WATTS LOSS | RING TERMINAL HOLE SIZE. |
|------|--------------|------------|-----------|---------------|------------|--------------------------|
| 5% Z | 15 | KLR21ERL3V | 21 | 29 | 69 | .25 |

| NO | REVISION | DATE | BY |
|----|----------|------|----|
| | | | |

| TOLERANCES (EXCEPT AS NOTED) |
|---------------------------------|
| DECIMAL |
| .XX ±.03 |
| .XXX ±.010 |
| FRACTIONAL |
| ± 1/16 |
| ANGULAR |
| ± 1/2° |

TCI 7878 N. 86th STREET
MILWAUKEE, WI 53224

**KLR SERIES 3 PH REACTOR
690V (FRAME E) ENCLOSED**

DRN BY DSW DATE 03/30/07 DWG NO. KLR21ERL3V/DG
SCALE TO FIT APPR'D SHT. 1 OF 1