



CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

690V	NEC MOTOR HP	CATALOG NO	__AMPS(A)	APPROX WT-LBS	WATTS LOSS	TERMINAL HOLE SIZE
5% Z	400	KLR420ECB5V	420	220	532	.53 DIA HOLE

TOLERANCES EXCEPT AS NOTED			7878 N. 86th STREET MILWAUKEE, WI 53224
DECIMAL			
.XX ±.03			
.XXX ±.010			
FRACTIONAL			KLR SERIES 3 PH REACTOR 690V (FRAME S) ENCLOSED
± 1/16			
ANGULAR			DRN BY DSW DATE 03/30/07 DWG NO. KLR420ECB5VDG SCALE TO FIT APPR'D SHT. 1 OF 1
NO	REVISION	DATE	BY