








CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

TOLERANCES EXCEPT AS NOTED
DECIMAL
.XX ± .03
.XXX ± .010
FRACTIONAL
± 1/16
ANGULAR
± 1/2°

TCI	7878 N. 86th STREET MILWAUKEE, WI 53224
KLR SERIES 3 PH REACTOR 690V (FRAME S) ENCLOSED	
DRN BY DSW	DATE 03/30/07
SCALE TO FIT	APPR'D [Signature]
KLR480ECB5VDG SHT. 1 OF 1	

690V	NEC MOTOR HP	CATALOG NO	__AMPS(A)	APPROX WT-LBS	WATTS LOSS	TERMINAL HOLE SIZE
5% Z	500	KLR480ECB5V	480	225	576	.53 DIA HOLE