



CUSTOMER IS RESPONSIBLE FOR INSTALLATION TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.

690V	NEC MOTOR HP	CATALOG NO	__AMPS(A)	APPROX WT-LBS	WATTS LOSS	TERMINAL RING HOLE SIZE
3% Z	50	KLR55DRL3V	55	36	90	.38 DIA HOLE

NO	REVISION	DATE	BY

TOLERANCES EXCEPT AS NOTED		TCI 7878 N. 86th STREET MILWAUKEE, WI 53224
DECIMAL	.XX ±.03 .XXX ±.010	
FRACTIONAL	± 1/16	KLR SERIES 3 PH REACTOR 690V (FRAME F) ENCLOSED
ANGULAR	± 1/2°	
DRN BY	DSW	DATE 03/30/07
SCALE	TO FIT	APPR'D
		DWG NO. KLR55DRL3VDG
		SHT.1 OF 1