



CUSTOMER IS RESPONSIBLE FOR INSTALLATION
TO MEET ALL NATIONAL AND LOCAL ELECTRICAL CODES.



7878 N. 86th STREET
MILWAUKEE, WI 53224

KLR SERIES 3 PH REACTOR
690V (FRAME B) ENCLOSED

DRN. BY DSW DATE 03/13/07 DWG. NO. CKLR8DQD1VDG
SCALE TO FIT APPRVD. SHT. 1 of 1

TOLERANCES (EXCEPT AS NOTED):			
DECIMAL			
.XX ± .03			
.XXX ± .010			
FRACTIONAL			
± 1/16			
ANGULAR			
± 1/2°			
NO	REVISION	DATE	BY

690V	NEC MOTOR HP	CATALOG NO	__AMPS(A)	APPROX WT-LBS	WATTS LOSS
3% Z	5	KLR8DQD1V	8	11	28