



TERMINAL BLK MARKING

BLOCK WIRE RANGE #18-#4 AWG  
FOR REACTOR AND TIGHTENING TORQUE. 20 LB-IN

CATALOG NO	VOLTS(V)	__mH±10%	__AMPS(A)	APPROX WT-LBS	TORQUE(LB-IN)
KLRUL18BTB	7.20	.620	18	10	20
KLRUL18FTB	8.62	.734	18	10	20
KLRUL21BTB	7.20	.525	21	10	20
KLRUL21FTB	8.62	.629	21	10	20
KLRUL25BTB	7.20	.441	25	10	20
KLRUL25FTB	8.62	.528	25	10	20
KLRUL27BTB	7.20	.408	27	10	20
KLRUL27FTB	8.62	.489	27	10	20
KLRUL35BTB	7.20	.315	35	11	20
KLRUL35FTB	8.62	.377	35	11	20
KLRUL45BTB	7.20	.245	45	11	20
KLRUL45FTB	8.62	.294	45	11	20

**TCI** Performance and Protection for Drives.

TRANS-COIL, INC  
MILWAUKEE WI  
WWW.transcoil.com  
800-824-8282

**KLR Series Line Reactor**

CATALOG # \_\_\_\_\_  
3PH, 60Hz, 600V Max, --- Amps  
40C Amb Max, 115C Rise  
Terminal Torque 20 LB-IN

UL US LISTED  
CE

NOTE: A1, A2, B1, B2, C1, C2,  
MARKINGS ON COIL AND TERMINAL BLOCK  
FOR REFERENCE ONLY.

NO	REVISION	DATE	BY	TOLERANCES EXCEPT AS NOTED	7878 N. 86th STREET MILWAUKEE, WI 53224  <b>KLRUL OPEN (FRAME D) LINE REACTOR</b>	DRN BY	DATE	DATE	DWG NO.	
				DECIMAL			DSW	05/10/04		B
				.XX ± .03 .XXX ± .01			SCALE	TO FIT	APPRV.	KLRULOPEN-5DG
				FRACTIONAL ± 1/32 ANGULAR ± 1/2°						SHT. 1 OF 1