


Tightening Torque 3 ± 0.15 Nm

### Technical data and measuring conditions.

|                                 |  |
|---------------------------------|--|
| Rated Voltage $V_R$             | 760/440 V AC, 50/60Hz.   |
| Rated Current $I_R$             | Referred to 40 °C ambient temperature                              |
| Test Voltage $V_{test}$         | 3270 V DC, 2 s (line/line)<br>3000 V DC, 2 s (line/case)           |
| Overload Capability (thermal)   | 1.5 · $I_R$ for 3 min per hour or<br>2.5 · $I_R$ for 30 s per hour |
| Leakage Current $I_{leak}$      | At 690 V AC, 50 Hz.  |
| Climatic Category (IEC 60068-1) | 25/100/21 (-25 °C/+100 °C/21 days damp heat test)                  |
| Approval Standards              | EN 133200, UL 1283, CSA C22.2 No. 8                                |
| Approval Markings               | UR, cUR  |

| $V_R$<br>AC<br>V | $I_R$<br>A | Terminal<br>cross section<br>mm <sup>2</sup> | $I_{leak}$<br>mA | $R_{typ.}$<br>m ohm | Approx.<br>Weight<br>kg. / lbs. |
|------------------|------------|--|------------------|---------------------|---------------------------------|
| 760/440          | 36         | 10   | < 7              | 3.8                 | 4 / 8.8                         |



|                    |  |  |  |                                 |        |   |                |
|--------------------|--|--|--|---------------------------------|--------|---|----------------|
|                    |  |  |  | TOLERANCES<br>(EXCEPT AS NOTED) |        | W132 N10611 Grant Drive<br>Germantown, WI 53022 |                |
|                    |  |  |  | DECIMAL                         |        |   |                |
| EDD 3959 ADDED     |  |  |  | 4/12/17                         | JRN    | .XX ±.02  |                |
| APPROVAL MARKINGS  |  |  |  |                                 |        | .XXX ±.01                                       |                |
| A UPDATE APPROVALS |  |  |  | 6/13/11                         | DSW    | FRACTIONAL<br>± 1/32                            |                |
| NO REVISION        |  |  |  | DATE                            | BY     | ANGULAR<br>± 1/2°                               |                |
|                    |  |  |  | SCALE TO FIT                    | APRVD. | DRN. BY DSW                                     | DATE 1/07/2010 |
|                    |  |  |  |                                 |        | DWG. NO. C KRF0036VTB                           |                |
|                    |  |  |  |                                 |        | SHT.1 OF1                                       |                |