


- Note:
- 1.) Refer to schematic #28282-1 on units with network gateways.
 - 2.) 120Vac Input Power for the Display Interface PCB can be tapped off the Control Transformer 120Vac Output secondary fuse or provided externally. For external wiring, follow all NEC guidelines.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.	L	CT consistency	10/27/21	JSG	TOLERANCES (EXCEPT AS NOTED)	 W132 N10611 Grant Drive Germantown, WI 53022 © TCI, 2021		
	K	Added 120V tap note	6/21/21	MJS	DECIMAL			
	J	Input option note update	6/10/20	JSM	.XX ± .03			
	H	Add 14 Ga CPT text	2/6/18	MJS	.XXX ± .010	Schematic, Active Filter 150 Amp		
	G	4196 add ct harness	11/10/17	MJS	FRACTIONAL ± 1/32			
	F	added 208V T1 wiring	7/20/17	MJS	ANGULAR ± 1°	DRN. BY RHW	DATE 4/14/14	DWG. NO. 29070
	NO	REVISION	DATE	BY		SCALE N/A	SIZE A	SHT. 1 OF 1